

191  
05-0523

### Report

An estimate amounting Rs. -127952.00 Rs Only has been framed to cover the cost for new connection ..P.T.W..(L.M.V.-S). f of 11 KV Dehrauchh. Feeder place ..Churehta..... 33/11 KV S/S ...Ganiva... Under scheme deposit.

In this estimate is load ....S.H.P. App no ..1008267000... Name Mr./Mrs. ....Laksh S/O ....Shivmahan.....  
.Village ....Churehta..... Block ..Rannagar..... Chitrakoot under head FULL DEPOSITE Sanction load S.H.P. Ref. no. ....  
proposed line will be tapped from.....Dehrauchh..... LINE Emanating from 33/11 KV S/S Ganiva .Chitrakoot.

The rate Provided in the estimate are as per Cost Data Book of RESPO Lucknow in market rate.


The work will be carried out by the section holder with the supervision of SDO EDSD-GANIVA.

" आवेदक द्वारा कराये गये सर्वे के अनुसार लाइन बनने में किसी प्रकार का विवाद या समस्या की स्थिति में आवेदक स्वयं जिम्मेदार होगा।

*Devkumar*  
JE Ganiva

*RAJAPUR*  
SDO

*Devkumar*  
JE Ganiva  
33/11 KV S/S  
GANIVA



Report Estimate for new connection of Lavlesh s/o Shiv Mahan R/O  
ajhurehka Block Ramnagar Processing fee 100/-  
 Application No. 1008207000 Dated 1/1/

Sn	name of material	unit	qty	rate	Amount in rs
1	pcc pole 8.5 mtr	no	07	2721	19047.00
2	acsr weasel cond	km	1.1	23984	26383.00
3	t off channel	no	01	478	478.00
4	t off channel clamp	no	01	304	304.00
5	v type cross arm	no	05	744	3720.00
6	cross arm holding clamp for pcc	no	05	304	1520.00
7	stay set rod	no	03	1627	4881.00
6	earthing set complete	no	02	838	1676.00
8	25 kva 11/4 kv t/f	no	01	56780	56780.00
9	t/f base angle	no	02	1778	3556.00
10	top channel	no	01	832	832.00
11	dropper channel	no	01	748	748.00
12	top/ drooper clamp	no	04	304	1216.00
13	pin insulator 11kv	no	15	268	4020.00
14	11kv disc insulator	no	06	384	2304.00
15	f brackets	no	05	265	1325.00
16	stay wire	kg	15	20	300.00
17	3 phase 4 wire meter with box	no	01	2921	2921.00
					132011.00
					+5941.00
					137952.00
	Total Cost Material				
	T&P 4.5%				
	Sub Total				

SDO

Junior Engineer  
 JUNIOR ENGINEER