

79
09/05/2023

Estimate


Electricity Distribution Division - 1st Bareilly

An estimate amounting to Rs. 139799.00 only has been framed to cover the cost for giving 08 HP PTW connection to the name of Shri. Nattho den w/o or s/o Kadhe.
 Village Pachitaur Post Kusari
 Block Lampur Jafarabad Tehsil Aonla Distt. Bareilly
 The line will be tapped from Antua (AG) Feeder S/
 Of village Pachitaur emanating from 33/11 KV S/S Bishharatgaj (Antua)
 Load has been sanctioned vide O.M. 1008269227 Dated 07/05/2023

1KV line existing at well - Pachitaur

manpal

Line Chart



Brief: Antua (AG)

- 1- H.T. Line - 160mtr.
- 2- L.T. Line - Nil
- 3- 25 KVA S/S - at No. proposed
- 4- Cable - 15 mtr
- 5- Load on L.T. 08 HP

ELECTRICITY DISTRIBUTION DIVISION
AONLA

Sanctioned For Rs. 139799.00
 Rs. One lac thirty nine thousand seven hundred ninety nine only.
 Chargeable Head Domestic
 Chargeable To UPPCL Ltd. Nil
 SI.No. 781500 - J/S/S/Bish
 During The Year 2023-24

Yecim
JELT

Certified that:

- 1- Connection is technically feasible.
- 2- Boring
- 3- Voltage drop is under permissible limit to consumer under consideration.
- 4- Connection shall be released from existing/proposed transformer.

Abstract of cost (As per cost data book 2016)

1- Line H.T. <u>160</u> Mtr. @ <u>236.00</u> = <u>37760.00</u>
2- Line L.T. <u>Nil</u> Mtr. @ <u>270.00</u> = <u>0.00</u>
3- Cost of 25 KVA S/S (1/3 or Full as the case may be) = <u>94582.00</u>
Total Rs. <u>132342.00</u>

Subsidy allowed to consumer (max. 68000.00 only)

A. Subsidy chargeable to UPPCL	<u>Nil</u>
B. Cost chargeable to consumer	
1- Processing charges	Rs. 100.00 ✓
2- Fixed charges	Rs. 5000.00 ✓
3- Cost after subsidy	Rs. <u>132342.00</u> ✓
4- System loading charges @ Rs. 300.00/KW	Rs. <u>2900.00</u> ✓
5- Security @ 300.00/HP	Rs. <u>139799.00</u> ✓
Total (1 to 5)	Rs. <u>139799.00</u> ✓
Grand total (A + B)	Rs. <u>139799.00</u> ✓

S.D.O.

J.E.

