


Electricity Distribution Division Rural Kasganj

Line Chart

Single Line Diagram showing arrangement with Details for Giving Supply to PTW of UHP to

Shri. Ram Bhajan S/O Sagar Ram
 village ~~Motla~~ Dharampur, Ganjdundwara,
 HPP No - 1008281627



Feeders - Weasel Bank

Letter No - 207
 Date - 31/05/2023

• - Pole
 ⊙ - Pole
 L - Stay Set

- | | | | |
|----|---|----|----------------------|
| 1 | Length of H T Line/Conductor..... 150m ckt | 2 | No. of Stay Set..... |
| 3 | No of support PCC Pole (8.5Mtr.)..... 03 + 02 NES | 4 | No of Earthing..... |
| 5 | Capacity of existing T/F..... | 6 | |
| 7 | Capacity of Proposed T/F..... 25 kVA | 8 | Proposed load..... |
| 9 | Length of conductor ACSR Weasel..... | 10 | No of tapping..... |
| 11 | G I wire 6/8 SWG for earth/Neutral..... | | |

M. Chandra Prasad
 Sub Divisional Officer
 Ganjdundwara KASGANJ

S. K. Singh
 Jr. Engineer
 33/11 KV Sub Station
 Ganjdundwara Kasganj

Electricity Distribution Division Rural Kasganj

Technical Report

An estimate Ammounting to Rs.only has been framed to cover the cost of estimate for providing supply to PTW of 13 H.P. to Mr Rom Bhajan S/o Syaram Vill- Dharampur, Ganjdundwara, Ksj. in reference to Letter No.207 Dt. 31/05/2021..... from EE ED Rural Kasganj And Jhatpat Applicaion No: 1008281627.

Site Location- Vill- Dharampur, Ganjdundwara, Kasganj.

This Work will Be supervised by SDO-I and done by J. E. Ganjdundwara Kasganj. The rates are as per respo by UPPCL. The Line Chart of the site is attached with this estimate.

Mohammed
S.D.O.I

EDSD Ganjdundwara KASGANJ

Abdullah
J.E.

33/11 KV S/S Ganjdundwara KSJ

Scanned by TapScanner