

689
29/06/23

301
30/06/2023


fuel Deposit
Aonla

Estimate

Electricity Distribution Division - 1st Bareilly

An estimate amounting to Rs. 106759=00 only has been framed to cover the cost for giving..... HP PTW connection to the name of Shri. Nankhesingh W/O or S/O. Rampal Singh
Village... Crami PO: Crami
Block... Mangawan Tehsil... Aonla Distt... Bareilly.
The line will be tapped from Sadanpur Ag. feeder S/S
Of village... Crami emanating from 33/11 KV S/S Ag. Aliganj
Load has been sanctioned vide O.M. 1008290926 - Dated 017/6/23

11 KV
Sadanpur
Ag feeder



New Connection proposed
Nankhesingh S/O Rampal
Vill - Crami

Brief:

- 1- H.T. Line - 20 MTR
- 2- L.T. Line - 4
- 3- 25 KVA S/S - 1 No. Existing
- 4- Cable - 15 MTR
- 5- Load on L.T.

ELECTRICITY DISTRIBUTION DIVISION
AONLA

Sanctioned For Rs. 106759=00
Rs. One lac six thousand seven hundred fifty nine only.
Chargeable Head... Fuel
Chargeable To UPPCL Ltd.
Sl.No. 301/500-III Ram/Ali
During The Year 2023-24

Certified that:

- 1- Connection is technically feasible.
- 2- Boring
- 3- Voltage drop is under permissible limit to consumer under consideration.
- 4- Connection shall be released from existing/proposed transformer.

Abstract of cost (As per cost data book 2016)

1- Line H.T. 20 Mtr. @ 236/.....	4720=
2- Line L.T. Mtr. @	
3- Cost of 25 KVA S/S (1/3 or Full as the case may be	9402=
Total Rs.	99302=

Subsidy allowed to consumer (max. 68000.00 only)

A. Subsidy chargeable to UPPCL	
B. Cost chargeable to consumer	
1- Processing charges	Rs. 100.00
2- Fixed charges	Rs. 5000.00
3- Cost after subsidy.....	Rs. 99302=
4- System loading charges @ Rs. 300.00/KW	Rs. 2400=
5- Security @ 300.00/HP	Rs. 106759=

Total (1 to 5)
Grand total (A + B)

Rs. 100.00 4957= ✓
Rs. 5000.00 99302= ✓
Rs. 2400= ✓
Rs. 106759= ✓
Rs. 106759= ✓

J.E.
Amp
JE
S/O Aliganj