

TECHNICAL FEASIBILITY REPORT

- 1- Name of Party & Address Shri Ram Narayan
- 2- Site of Location 821 Madhu
- 3- Load required Villages: Pire Shamser Singh
0811P
- 4- Existing Load If any _____
- 5- Manufacturing process Agriculture
Sub-station and its capacity from 20MVA / Adon
which supply is to be given _____
- 7- Capacity of existing T/F Feeder 25kVA / (New)
and present position of load on it _____
- 8- Whether there exists adequate distribution
same in the area Yes
- 9- Is there any other's connection in
same permission? NO
- 10- Distance of unit from sub-station 0.5 km
- 11- Is there permission in under disputes, NO
- 12- Whether increase in capacity of Sub Station or transformer shall be required for given
the load NO
- 13- Is there or any connection in the name of consumers his father brother and wife
to? NO
- 14- Whether it would require construction of new sub-station if yes by which time it would
be possible Yes
- 15- Whether the building is needed permanent connection yes

SUMMARY OF T.F.R.

Load required technically feasible.

OR

Load required is not technically feasible till.

Note:- Please attach line diagram if necessary.

J.E.

33/11 KV S/S Adon

SDO-III

EDSD-ATAURA