

ELECTRICITY DISTRIBUTION DIVISION-BILASPUR

ESTIMATE FOR P.T.W/PUMP SETS

Name of Applicant

1. Sri/Smt. Sukhward Singh & Bhajan Singh
 2. Village: Beebana
 3. Block Bilaspur Watt

Village Beebana

Load of P.T.W.

H.P.

Code No.

Associated Light & Fan

Head	Detail of Line and S/S	Unit	Qty.	Rate Rs.	Amount
2061003	11 KV Line of PCC Pole with ACSR to Board	KM			
	Weasel	KM.			
	C.H. to Consumer	KM.			
	L.T. Line 3 PH. 4 Wire on P.C.C. to Board	KM.			
	With A.C.S.R	KM.			
	C.H. to Consumer	KM.			
2060302	Now S/S 11/0.4 KV <u>100</u> KVA or increasing capacity of Existing S/S from <u>100</u> KVA to <u>100</u> KVA.	No.	<u>1</u>	<u>31527/-</u>	<u>31527/-</u>
2060302	System Loading Charges			<u>32110/-</u>	<u>32110/-</u>
020611	Inspection Fee of Electrical Inspector	I.S		<u>100/-</u>	<u>100/-</u>
020611	Fixed Charges for Service Line type A/B/C Chargeable to Board	Each			<u>4957/-</u>
020611	Fixed Charges for Service Line type A/B/C Chargeable to Consumer	Each		<u>5000</u>	<u>5000/-</u>
020611	Variable Charges for Bare Conductor CH to Consumer.	Mtr.			
	Variable Charges for Cable Conductor CH to Consumer.	Mtr.			
1-	Total Amount Chargeable to Board Rs. <u>NIL</u>				
2-	Total Amount Chargeable to Consumer Rs. <u>33610/-</u>				
	Total <u>36404/-</u>				<u>36404/-</u>

REPORT

This estimate amounting Rs. 33610/- only has been framed to cover the cost & G.S. to P.T.W. The 11 KV Line will be tapped from Rampura feeder emanating from 33/11 KV S/S A. Nagar. The load on existing 100 KVA Transformer is 7.5 H.P. or there is no existing T/F from which the load of prospective consumer can be connected. IN the estimate a new Sub-Station of 100 KVA have been proposed/increasing capacity of existing 100 KVA T/F has been proposed to be increased by 100 KVA T/F.

- 1- Certified that estimate has been framed as per latest rate shedule of U.P.P.C.L.
- 2- The proposed site of P.T.W. is beyond 200 m from S.T.W. No.
- 3- The proposed site of P.T.W. is beyond 100 m from canal having top with 25 feet
- 4- Certified that the connection shall not be given from S.T.W. Transformer.
- 5- The boaring of prospective Consumer Exist.

Junior Engineer

Sub-Divisional Officer

Sanctioned of Rs. 36404/-

Ch. Head	Ch. To Cons.	Ch. To Crop.	Total
O/H	<u>✓</u>	<u>—</u>	<u>—</u>
S/S	<u>31527/-</u>	<u>—</u>	<u>31527/-</u>
M/E	<u>4957/-</u>	<u>—</u>	<u>—</u>
Inspection Fee	<u>—</u>	<u>—</u>	<u>—</u>
System loading	<u>—</u>	<u>—</u>	<u>—</u>
Total	<u>36404/-</u>	<u>—</u>	<u>36404/-</u>

San. No. 84/232-22C/23-24/27/04/08/23BC-487

D/MAN

D.A.(W)

EE.

