



कार्यालय
उपखण्ड अधिकारी
विद्युत वितरण उपखण्ड (चिलबिला)
प्रतापगढ़ (उ०प्र०)

पत्रांक/ C/609B /वि०वि०उपखण्ड चिलबिला प्रता०/

दिनांक:- 16/9/2023

विषय:-आवेदक द्वारा एल०एम०वी०-5 श्रेणी के अन्तर्गत स्थायी संयोजन विद्युत भार 03 हा०पा० की स्वीकृति हेतु तकनीकी आख्या प्रस्तुत के सम्बन्ध में।

अधिशाली अभियन्ता
विद्युत वितरण खण्ड-प्रथम
जनपद-प्रतापगढ़।

कृपया उपरोक्त विषयक में/ श्री विष्णुप्रसाद उल्ला सुत श्री श्री० इश्वरिणी
पता व ग्राम (मजरा) सराम राजई पोस्ट-सराम राजई जनपद-प्रतापगढ़ के
बिन्दुकर (TFR/SIR) निम्नवत है:- App.No. 1008323403

01	आवेदित परिसर पर पूर्व में बकाये की स्थिति का विवरण।	नही
02	आवेदित परिसर पर पूर्व में कोई संयोजन का पूर्ण विवरण।	नही
03	परिसर की निकटतम H.T/L.T मेंस से न्यूनतम दूरी।	30 मी०
04	वितरण परिवर्तक के अतिभारित की स्थिति	अतिभारित नही
05	11KV पोषक के अतिभारित की स्थिति।	अतिभारित नही
06	33/11 KV उपकेन्द्र के पॉवर परिवर्तक की स्थिति।	अतिभारित नही
07	मीटर स्थापन हेतु परिसर पर उपलब्ध स्थान की स्थिति।	उपलब्ध
08	परिसर पर संयोजन का प्रयोग (वाणि०/कृषि/ आवासीय/अन्य)।	कृषि
09	परिसर पर निर्मित भवन का विवरण (एकल/बहु)।	शकल गजिल
10	अन्य तकनीकी आख्या।	

सूचनार्थ एवं आवश्यक कार्यवाही हेतु प्रेषित।


अवर अभियन्ता

चिलबिला


उपखण्ड अधिकारी
विद्युत वितरण उपखण्ड चिलबिला
प्रतापगढ़

Electricity Distribution Division, Pratapgarh

ESTIMATE

Estimate framed by S.D.O I, II, III, IV chilbila (2023) for giving
 supply to Shri Kifayatulla S/O Mohd. Ibrahim
 village Sarai Rajai Post Sarai Rajai Block mangrauna
 District Pratapgarh Load 03 HP /HP P.T.O Total

1- 11 KV line.....KM	Unit Cost	P/K.M.	Rs.
onsupports	Vide Shedule No.		
2- L.T. line 3 phase.....KM	@ Rs.	P/K.M.	Rs.
onsupports	Vide Shedule No.		
3- Extra cost for Section poles	Rs.		Rs.
	Vide Shedule No.		
4- Extra cost for tree off	Rs.		Rs.
	Vide Shedule No.		
5- Extra cost for underground cossing	Rs.		Rs.
	Vide Shedule No.		Rs.
6- Extra for	As per details enclosed.		Total Rs.
Length of line chageable to the Board	Meters		
Length of line chageable to the con	Meters		
summers beyond free limit	TotalMeters		
7- (a) 11/4 KV Sub Station.....Rs.	Vide Shedule No.		Rs.
(b) Increasing capacity from	Rs.		Rs.
.....KVA toKVA	Vide Shedule No.		Rs.
8- Cost of Service Line as per detail	Rs.		Rs.
enclosed.			Rs.
(a) Meter Cost	Rs.		Rs.
(b) System Loading charges	Rs.		Rs.
(c) Fixed Charges	Rs.		Rs.
(d) Secuirty Charges	Rs.		Rs.
	Grand Total Rs.		Rs.

The H.T./L.T. line would be tapped from Madafarpur feeder sub-station in
 village Sarai Rajai emnating from 132/33/11 KV Sub-station at salhipur kanjas

Certified that the costing of the works involved has been done according to Standard schedules framed in
 the Division on current stock issue rates.
 Line chart on its back.

Junior Engineer
 Checked by-

Allocation Checked

D/Man/Tech.Asstt.

Divisional Accountant (works)

Sub-Divisional Officer
 Estimate Sanctioned
 No.


No. /of date

Copy to :-

- 1- Sub-Divisional Officer
- 2- Divisional Accountant (W)
- 3- Assistant Engineer (Store)

Executive Engineer

Executive Engineer



LINE CHART

03HP P.F.W

Sri Kifayat Ullah s/o Mohd Ibrahim
vill. sarai Rajai

Block - Mangrauna

S/S - Salhipur Kanjias

Feeder - Madafampur

Under BPSP Chulbila

Dist. Pratapgarh

Requirement

- | | |
|---------------------------------|--------|
| 1- P.C.C. pole 8.5 mtr..... | No |
| 2- ACSR weasel conductor..... | mtr. |
| 3- Gal wire SWG..... | KG |
| 4- Stay rod..... | No |
| 5- Stay wire 7/10 swg..... | KG |
| 6- Earthing Rod..... | No |
| 7- T/F.....KVA..... | No |
| 8- Length of line | 30 mtr |

Voltage Drop Calculation

S.D.O.

Jr. Engineer
Chulbila

30 mtr long cable connection cable provide by consumer