

DAKSHINANCHAL VIDYUT VITRAN NIGAM LTD.
ELECTRICITY DISTRIBUTION DIVISION (I), AGRA

Estimate for Giving Supply to Shri KARAM SINGH

S/o Shri RAMJI LAL
Address KHASRA NO-272,
VILLAGE LOHKERERA,
AGRA (U.P.)
Dist-Agra

Sanction No.
Date.....
P. F. No. <u>P.53776365</u>
Date.....

Sanctioned Load 13 H.P B.H.P./K.W./K.V.A. Process DEPOSIT (PTO)
Vide OM No. 6899 Dt. 26/08/2022 Name of 33 KV S/S. PANWARI
Name of Feeder 11KV KEETHAM FEEDER

REPORT

The enclosed estimate amounting to Rs. ₹ 1,41,782 = 00 under the head 1,41,782 = 00
DEPOSIT Chargeable to Corp. Chargeable to consumer ₹ 1,41,782
(PTO) has been framed to cover the cost for construction of 200mtr Mtr. of 11 KV.
 Mtr. of low tension transmission line with 95KVA 11/0.4KV 3φ TF
Rural/PTV/Town type S/S for feeding 13 H. P. Load and giving Service
connection to Shri KARAM SINGH s/o RAMJI LAL

The proposed line be tapped from existing 11KV KEETHAM FEEDER
feeder at VILLAGE LOHKERERA (Place) The details of works involved in the estimate as per P.V.V.N.L.
practice. The supply shall be given by constructing Tee off 11 KV/LT. Line 200mtr Mtr.
long which shall be tapped from existing 11KV KEETHAM feeder emanating from
33 11 KV Sub-Station PANWARI Where sufficient spare capacity is available to
cover the load.

The Connection is technically feasible by providing 9.5 KVA existing 11/0.4 KV Substation

The proposed line involves construction of No.
Cable crossing No. L.T. cable crossing No.
and crossing and No. overhead/underground Railway crossing.

The rates provided in estimate as per current rates of C.M. RESPO Lucknow vide letter No. 1273/GM/RESPO-Dt-3.06.2003

Of
Junior Engineer

AKD
Sub-Divisional Officer

Executive Engineer