

निजी वलकृत संगीत

DAKSHINANCHAL VIDYUT VITRAN NIGAM LTD.
ELECTRICITY DISTRIBUTION DIVISION (I), AGRA

Estimate for Giving Supply to Shri..... SURSEH

S/o Shri..... GANESH PRASAD

Address..... KHARWA NO. 611,
VILLAGE MANWARA, GUNJAN,
AGRA C.P.

Distt-Agra

Sanction No. 3551

Date 02/11/2013

P. F. No. PS3257662

Date 06/11/2013

Sanctioned Load..... 10HP B.H.P./K.W/K.V.A. Process..... DEPOST (PTW)

Vide OM No. 2557 Dt. 02/11/2013 Name of 33 KV SIS..... RUNAKTA

Name of Feeder..... 11KV AKBARA FEEDER

REPORT

The enclosed estimate amounting to Rs. ₹ 1,02,680 under the head DEPOST Chargeable to Corp. Chargeable to consumer has been framed to cover the cost for construction of 50mtr Mtr. of 11 KV. and Mtr. of low tension transmission line with 25KV/110KV TIF Rural/PTW/Town type SIS for feeding..... 10HP H. P. Load and giving Service connection to Shri..... SURSEH s/o SHRI GANESH PRASAD

The proposed line be tapped from existing 11KV AKBARA FEEDER feeder at KHARWA No-611, VILLAGE MANWARA, GUNJAN (Place) The details of works involved in the estimate as per D.V.V.N.L. practice. The supply shall be given by constructing Tee off 11 KV/LT. Line..... 50mtr Mtr. long which shall be tapped from existing 11KV AKBARA feeder emanating from 33/ 11 KV Sub-Station..... RUNAKTA Where sufficient spare capacity is available to cover the load.

The Connection is technically feasible by providing 25 KVA existing 11/0.4 KV Substation

The proposed line involves construction of No. H.T. Cable crossing..... No. L.T. cable crossing..... No. road crossing and..... No. overhead/underground Railway crossing?

The rates provided in estimate as per current rates of G.M., RESPO Lucknow vide letter No. 3273/GM/RESPO Dt. 3.06.2003


Junior Engineer


Sub-Divisional Officer

Executive Engineer

Scanned with CamScanner