

TO  
THE EXECUTIVE ENGINEER  
EDD SHAHABAD HARDOI




Date: 5-01-2024  
TFR FOR PTW  
APPLICATION NO- 1003359242  
MOB NO- 8172931851

DIR.  
Please consider vide no. \_\_\_\_\_ /EDD-SHAHABAD HARDOI for reference, PF DATED .../...  
...2022.....Of your office, which is related to submission of technical feasibility report regarding sanction of electrical  
oad, so corresponding to this details are as...

Name of Applicant:- FAKHARUDDIN s/o- SAMIULLA	PROCESSING FEE -100 RUPEE
ADDRESS :- TUMURKI, SHAHABAD, HARDOI	CHALLAN NO: P53260782
MNDP.HR. PDOSGJ	DATED: 12-12-2023

1	IS LOCATION OF CONN IS LOCATED INSIDE THE BORDER OF RURAL AREAS OR NAGAR PANCHYAT? - RURAL	
2	NATURE OF TAPPING FEEDER IS RURAL OR TOWN FOR PROPOSED LINE/CONNECTION - RURAL	
3	IS THERE ANY EXISTING ELECTRICAL CONNECTION ? IF YES THEN DETAILS - NO	
4	ACCOUNT NO-	DUE AMOUNT-
5	IS THERE PROPOSED DP/POLE MOUNTED S/S? - YES(25KVA)	LENGTH OF PROPOSED LINE-
6	NATURE OF SUPPLY- 0.4 KV (3PH,4-W)	NATURE OF PROPOSED LINE-11 KV(HT)
7	EXITING TECHNICAL DETAILS	
8	NAME OF 11 KV FEEDER- NARHAI JAMURA	CAPACITY OF POWER TF <sup>1ST</sup> -5MVA
9	LENGTH OF 11 KV FEEDER - APPROX -75 KM	LOAD CURRENT OF POWR TF- 290 A
10	LOAD CURRENT OF FEEDER- 200 A 190 A	REMARKS-FEEDER & POWER TF OVERLOADED

मिथे गले सोके के सोन मसके के  
रेवे लाइने को जोडने के लिए  
जिम्मेदारी हमारी है  
मिथे सोके के



Proposed pole mounted  
S/S with one 25 kVA  
T/F, for required / asked  
load of 8 HP.

Neeraj Kumar  
JUNIOR ENGINEER  
11006558  
PFA: 81AE 159516

Shashank  
SUB-DIVISIONAL OFFICER  
11006557

भारतीय न्यायिक



THE  
RUPEE

₹. 10

RS. 10



INDIA

INDIA NON JUDICIAL



संयुक्त कोमाण विद्युत व पश्चिम सि. महोदय शाहबाद

UTTAR PRADESH

81AE 159516

सपत पत्र

मैं जयशंकर सिंह डा. लक्ष्मी उल्ला दुधुवा पारसट दुधुवा एला

शाहबाद जिला हरदोई का वासी हूँ  
मैं कि गाटा सं 300 आरजी ग्राम दुधुवा का आज दिनांक 5-1-2024  
विद्युत निचामा द्वारा करे निजी नाल रूप हेतु सेव किया गया  
जिसमे 10 मीटर दूरी प्राप्त हुई है जो मेरे सम्पत्त की गई जिसका  
उकलन मुझे दिया जाये

जै यह है कि मेरे निजी नाल रूप जिसकी दूरी व गाटा संख्या  
उल्लिखित पाई जाती है तो इसकी जिम्मे दारी मेरी होगी  
जो भी वास्तविक कार्यवाई जाये तो मुझे मजबूर है खर्च लागू कर  
बनवाने की पूर्ण जिम्मे दारी मेरी है

उपरोक्त सपत पत्र मे जो भी लिखा गया वो सत्य है वो सत्य है

AFFIDAVIT OF IDENTIFIED BY डा. लक्ष्मी उल्ला  
SOLLEMONY AFFIRMED & VERIFIED AT  
TAH. SHAHABAD (HARDOI) U.P. INDIA  
DATE 5/1/24  
DEPONENT जयशंकर सिंह NO. 5/1/24

डा. लक्ष्मी उल्ला  
जयशंकर सिंह