


पुत्र/पति - गोविन्दन केरमा - 1008364924 | तिथि 02.01.2024 | SRM002/JE(A) / 02.01.2024
पास

949
09/01/2024

Estimate

Electricity Distribution Division – Anna

An estimate amounting to Rs....120919=00 only has been framed to cover the cost
for giving 7.5.....HP PTW connection to the name of Shri Kali cheraam W/o or S/O Seri Bikkadha sen
Village Buchera Post. Ali Gram.
Block Mujhgawan Tehsil. Aonla Distt. B.R.D.
The line will be tapped from ...11 KV Ali Grami feeder S/S
Of village Ali Grami emanating from 33/11 KV S/S AG Grami
Load has been sanctioned vide O.M. Dated



Brief:

- 1- H.T. Line → 80m+
 - 2- L. T. Line → NIL
 - 3- 25 KVA S/S → 0.140
 - 4- Cable → 20m+
 - 5- Load on L.T. → 7.15TP

Certified that:

- 1- Connection is technically feasible.
 - 2- Boring
 - 3- Voltage drop is under permissible limit to consumer under consideration.
 - 4- Connection shall be released from existing/proposed transformer.

Abstract of cost (As per cost data book 2016)

1- Line H.T. Mtr. @ 2.36 = Rs 180.80 = Rs
 2- Line L.T. Mtr. @ = 945.82 = Rs
 3- Cost of 25 KVA S/S (1/3 or Full as the case may be Total Rs 11346.2 = Rs

Subsidy allowed to consumer (max. 68000.00 only)

- A. Subsidy chargeable to UPPCL
 - B. Cost chargeable to consumer

B. Cost chargeable to consumer	
1- Processing charges	Rs. 100.00 100=00
2- Fixed charges	Rs. 5000.00 4959=00
3- Cost after subsidy.....	Rs.
4- System loading charges @ Rs. 300.00/KW	Rs. 113462=00
5- Security @ 300.00/HP	Rs. 2400=00
Total (1 to 5)	Rs. 120919=00
Grand total (A+B)	

1

S.P.Q.

S.B.S.
EDSD II Ind
Ali Janj

R. H. Brown
J.E.
Alvion