

TO  
THE EXECUTIVE ENGINEER  
EDD SHAHABAD HARDOI




Date: 18/01/24  
TFR FOR PTW  
APPLICATION NO- 1008360122  
MOB NO- 7518092296

IR,  
Please consider vide no. \_\_\_\_\_ /EDD-SHAHABAD HARDOI for reference, PF DATED ...../.....  
2022..... Of your office, which is related to submission of technical feasibility report regarding sanction of electrical  
ad, so corresponding to this details are as...

Name of Applicant:- <b>BHAVNA w/o- SADANAND</b>	PROCESSING FEE -100 RUPEE
ADDRESS:- <b>Connection location: FIRWAN R/O- BASIT NAGAR, SHAHABAD, HARDOI.</b>	CHALLAN NO: <b>P53 86 2754</b>
<b>MVDP.HR.PD0670</b>	DATED: <b>15/12/23</b>

IS LOCATION OF CONN IS LOCATED INSIDE THE BORDER OF RURAL AREAS OR NAGAR PANCHAYAT? - <b>RURAL</b>	
NATURE OF TAPPING FEEDER IS RURAL OR TOWN FOR PROPOSED LINE/CONNECTION-- <b>RURAL</b>	
IS THERE ANY EXISTING ELECTRICAL CONNECTION ? IF YES THEN DETAILS-- <b>Non premise</b>	
ACCOUNT NO- <b>7036 596 000</b>	DUE AMOUNT- <b>6114 ₹ (PFA) decl<sup>m</sup></b>
IS THERE PROPOSED DP/POLE MOUNTED S/S? - <b>YES(25KVA)</b>	LENGTH OF PROPOSED LINE- <b>270m</b>
NATURE OF SUPPLY- <b>0.4 KV (3PH,4-W)-</b>	NATURE OF PROPOSED LINE- <b>11 KV(HT)</b>

EXITING TECHNICAL DETAILS	
NAME OF 11 KV FEEDER- <b>NARHAI</b>	CAPACITY OF POWER TF <sup>1ST</sup> - <b>5MVA</b>
LENGTH OF 11 KV FEEDER - <b>APPROX ~75 KM</b>	LOAD CURRENT OF POWR TF- <b>340 250 A</b>
LOAD CURRENT OF FEEDER- <b>200 A</b>	<b>REMARKS-FEEDER &amp; POWER TF OVERLOADED</b>



Neeraj Kumar  
JUNIOR ENGINEER  
KV S/S ANJHI SHAHABAD

Shahab  
SUB-DIVISIONAL OFFICER  
EDSD- SHAHABAD

Recommendation-Applicant/Consumer  
PFA: 8/AE - 166938



# भारतीय गैर न्यायिक

दस  
रुपये

रु.10



TEN  
RUPEES

Rs.10

INDIA NON JUDICIAL

उत्तर प्रदेश UTTAR PRADESH

81AE 166938

भदोदय,  
मेरा नाम भावना फुली श्री राम-प्रेम  
निकाली भ्रातृ पो. वासिस्तनगर, भाटा. सं. - 363 का  
कलम दिनांक 18-01-2024 को विद्युत विभाग द्वारा  
मेरे निजी नलकूप कनेक्शन हेतु सर्वे किया गया  
जिसमें 270 मी. इसी पाप हुई, जो कि मेरे समक्ष  
की गयी, जिसका पकवान मुझे दिया जाये। इसके अतिरिक्त  
यदि मेरे निजी नलकूप कनेक्शन की इसी दोड़ गाय संख्या  
की वीरिण पायी जाती है तो इसकी प्रतिलिपि अगोदर  
मेरी डोगी और जो श्री वैद्यनिक कंपनी की गायकी  
मुझे कहे र है श्वे लीडन कनेक्शन की प्रतिलिपि अगोदर  
मेरी कंपनी।

दिनांक - 18-01-2024

भावना