


App no - 1008368270

TECHNICAL FEASIBILITY REPORT

- 1-Consumer Name and Billing Address: Bhulaci s/o Bhagwati - parsa khurd
- 2-Applied Load in KVA/KW: 3HP
- 3-Voltage at which connection is required: 230
- 4-Capacity of T/F to be installed at consumer premises:
- 5-Metering required at single/multipoint: Single
- 6-load in Amp, if full applied load is used: -
- 7-Name of 33/11 kv s/s to feed the load: vetao
- 8-Name of feeder, with voltage, to feed the load: jina
- 9-Existing load on concerned feeder in Amp: 130 AMP
- 10-Capacity of concerned 33/11 kv T/F in Amp: 204 amp
- 11-Existing load of concerned 33/11 KV T/F in Amp: 120 amp
- 12-Releasing of applied load on existing system is technically feasible:

(yes/no)



JE

33/11KVS/S



(name)

SDO

EDSD

(NAME)

EE

EDO-D/genl