

विद्युत का रि.....विद्युत रोधी कम से कम एक मेगाओम होगा अथवा उतना होगा जितना भारतीय मानक संस्थान समय-समय पर विर्निमित किया जाय।

ठेकेदार द्वारा विद्युतरोधी प्रतिरोधी के परीक्षण का परिणाम-

फेज-1 व अर्थ	फेज-2 व अर्थ	फेज-3 व अर्थ
(I) फेज एवं अर्थ के बीच	<u>2</u>	<u>2</u>
(II) न्यूट्रल एवं अर्थ के बीच		
फेज-1 व अर्थ	फेज-2 व अर्थ	फेज-3 व अर्थ
(III) तारों के मध्य-	<u>2</u>	<u>2</u>

नियम- 29- 310

(I) बतायें कि वायरिंग का कार्य, प्रयुक्त सामाग्री तथा उपकरण भारतीय मानक संख्या PGH-121 की व्यवहार संहिता के अनुसार है।

(II) बतायें कि प्रत्येक सर्किंट अलग-अलग रिवर्चों द्वारा नियंत्रित है।

(III) बतायें कि सामर्त विद्युमन्य (जीवन्त) चालकों द्वारा लगाये गये हैं।

नियम- 32-

बतायें कि दो तार प्रणाली का अर्थवायर तथा बहुतार प्रणाली के भूसम्पर्कित न्यूट्रल वायर पर स्थाई प्रकृति का सूचक लगाया गया है जिससे कि ऐसे चालक का विद्युमन्य (जीवन्त) चालकों से सुभिन्न किया जा सके।

(सत्यापन प्रमाण पत्र)

मैं/हम मेरा सांई इलेक्ट्रिकल्स लाइसेन्स प्राप्त विद्युत ठेकेदार लाइसेन्स संख्या PGH-121 निम्न का सत्यापन करते हुए घोषणा करते हैं कि -

- (अ) पूर्वोक्त विद्युत संस्थापन मेरे द्वारा किया गया है।
- (ब) पूर्वोक्त विद्युत संस्थापन का विद्युतरोधी का परीक्षण मेरे/हमारे सुपरवाइजर द्वारा किया गया है एवं उसका परीक्षण परिणाम मेरे/हमारे सुपरवाइजर द्वारा अंकित किये गये हैं।
- (स) संस्थापक कार्य भारतीय विद्युत नियम 1956 एवं भारतीय मानक संस्थान की व्यवहार संहिता के प्राविधानों के अनुरूप किया गया है।
- (द) उपरोक्त कार्य मेरे/हमारे निम्नांकित स्टाफ द्वारा किया गया है।

वायर मैंन का नाम श्री ललित कुमार पाल परमिट संख्या- 41811 वैधता तिथि- 27-08-2024

अप्रिन्ट्स का नाम एवं हस्ताक्षर

दिनांक:

विद्युत ठेकेदार के फर्म का नाम

मे० साईं इलेक्ट्रिकल्स

पूरे नरसिंहभान, भंगवा चुंगी, प्रतापगढ़


लाइसेन्स संख्या-121

लाइसेन्स श्रेणी-“ग”

वैधता का दिनांक ०१.०३.२०१५

मे० साईं इलेक्ट्रिकल्स

ठेकेदार के हस्ताक्षर




घोषणा

(उपभोक्ता द्वारा की जाय)

मैं प्रमाणित करता हूँ कि राज्य विद्युत परिषद् लाइसेन्सी द्वारा विद्युत ऊर्जा के प्रदाय हेतु निर्धारित शर्तों एवं भारतीय विद्युत नियम, 1956 के प्राविधानों के अनुपालन मेरे द्वारा ठीक प्रकार किया गया है। मुख्य फ्यूज की अधिकतम क्षमता..... १६..... एम्पियर से अधिक नहीं है तथा संस्थापन में किसी प्रकार की बढ़ोत्तरी अथवा ओवर लोडिंग राज्य विद्युत परिषद् लाइसेन्सी द्वारा प्राप्त होने पर ही की जायेगी।

दिनांक ०२.०१.२३


उपभोक्ता का नाम एवं हस्ताक्षर

परीक्षण रिपोर्ट

(सप्लायर के प्रतिनिधि द्वारा भरी जायेगी)

विद्युतरोधी प्रतिरोधों का परिणाम

फेज-1 व अर्थफेज-2 व अर्थफेज-3 व अर्थ

(1) फेज एवं अर्थ के बीच-

फेज-1 व अर्थफेज-2 व अर्थफेज-3 व अर्थ

(2) तार एवं अर्थ के बीच-

विद्युत संस्थापना में पाई गई कमियाँ (यदि कोई हो) एवं कमियों को दूर कराने हेतु कृत कार्यवाही-

(1)

प्रदायकर्ता (सप्लायर) के निरीक्षणकर्ता

(2)

का नाम एवं हस्ताक्षर

(3)

पदनाम

(4)

दिनांक.....

INDIAN ELECTRICITY RULES 1956
Statement in regard to the Compliance with the
requirements of rule 33, 50, 51 and 61

The attention of the consumer is drawn to the rules mentioned above in regard to the supply of energy at medium pressure, sanction to use of energy at this pressure can not be given unless all provision of the said rules have been completed with the consumer must submit this from in duplicate along with treasury challan after replying and signing each of the following questions both myself and be the electrical contractor who has done the wrighting work of the suppliers office for verification. If the installation on test and verification is found in order it will be connected and the statement will be counter regned by the supplier and forwards to the Electrical Inspector to Government of Uttar Pradesh for Final inspection and test

Questions	Reply	Owners	Remarks of the Electrical Inspector
			Signature
1	2	3	4
(a) Have you affixed departmentry in a conspicuous position a acaution notice in Hindi with word " सावधान" on a sheet it on plate of not less than "12x9" size in red letters on white background [Rule 35(a)]			Yes/No
(b) In a suitable iron-cald linked switchd or circuit break or request capacity to carty and breack and breack the current placed in each conductor as a neera possible to but after the point commencement of supply? [Rule 50(1)(1)]			Yes/No
(c) Have you installed a suitable iron-cald linked switch or circuit breaker of requeste in capacity in such a position as to abiacent to the motor other apparatus readily accesible to and easily operate by tee person incharge to cut of the supply frromt he motor or apparatus etc. [Rule 50 (1)(a)]			Yes/No
(d) Are all conductor completely enclosed inmachinically strong metal casing or metalli ccovering? [Rule 50(1)(a)]			Yes/No
(e) Has a clear space of not less than 3 free in which been provided in front of the switch bord? [Rule 51(1)(c)(1)]			Yes/No
(f) If there are any attachment of bare connections of the pack of the switch boards is the space behind the switch board less than 9 inches or more than 30 inches in with. [Rule 51 (1)(c) (it)]			Yes/No
(g) If the behind the switch board exceeds 30 inches in with is there passage way clear height of 6 feet? [Rule 51 (1) (c) (II)]			
(h) Has the frame of your motor meallic parts of all transformers and any other aporatuts used for regulating or controlling energy earthed by two sapre and distant connection with earth? [Rule (61) (21)]			Yes/No
(i) What is the earth resistance of earth connection.			
(ii) Licensers earth.	✓		
(iii) Consumer earth.			
(j) Have you deposited the prescribed the fee for the inspection by the Electrical Inspector, Under the head. 043 विद्युत पर कर एवं शुल्क 102 भारतीय विद्युत नियमावली के अन्तर्गत शुल्क।			Yes/No

T.C.No.

Date.....